

FLASHING AS SPECIFIED

WOOD BLOCKING AND PLYWOOD AT 5° SLOPE

NON-COMBUSTIBLE FIBERGLASS BATT INSULATION ON VAPOR BARRIER

BRICK VENEER c/w 1" (25mm) AIR SPACE AND BRICK TIES

EPS CANT STRIP

FIBER BOARD SUBSTRATE w/ ROOF MEMBRANE ON 3 1/2" (89mm) RIGID INSULATION

FORM PANELS c/w INSERT WEBS- CUT TO SUIT ROOF CONNECTION- ADDITIONAL FORM SUPPORT AS REQUIRED

ALLOW ROOF SLAB TO REST ON TO BEARING WALL CONCRETE

EPS FOAM REMOVED AT JOIST LOCATION ONLY TO ALLOW JOIST PLACEMENT

PROPRIETARY STEEL JOIST ROOF SYSTEM

WET SET DOWELS TO MATCH VERTICAL REINFORCEMENT BETWEEN POUR OR AS SPECIFIED

HORIZ/VERT REINFORCEMENT AS PER CODE OR AS SPECIFIED

CEILING FINISH AS PER STEEL JOIST MANUFACTURERS SPECIFICATION (NOTE: WHERE GYPSUM BOARD IS REQUIRED TO COMPLETE FIRE RATED ASSEMBLY, EPS FOAM KERF CUT TO ENABLE CEILING FINISH TO PROVIDE THERMAL BARRIER CONTACT TO CONCRETE)

NUDURA 12" (305mm) STANDARD FORM UNIT

1/2" (13mm) GYPSUM BOARD

**DISCLAIMER NOTICE:**  
SPECIFIC INFORMATION REQUIRED FOR COMPLIANCE WITH LOCAL CODES IS THE RESPONSIBILITY OF THE DESIGNER



# NUDURA

INTEGRATED BUILDING TECHNOLOGY

*Building Value.*

NUDURA 12" (305mm) FORM UNIT  
STEEL JOIST ROOF SYSTEM  
EXTERIOR BEARING WALL  
BRICK VENEER FINISH

REV. NO.  
003 KS

DWG NO.  
F12F01

DATE:  
APRIL 2010

DRAWN BY:  
T. VAN CLIEAF

SCALE:  
1 : 8