

FLASHING AS SPECIFIED

WOOD BLOCKING AND PLYWOOD AT 5° SLOPE

NON-COMBUSTIBLE FIBERGLASS BATT INSULATION ON VAPOR BARRIER

EXTERIOR FINISH AS SPECIFIED

EPS CANT STRIP

FIBER BOARD SUBSTRATE w/ ROOF MEMBRANE ON 3 1/2" (89mm) RIGID INSULATION

CONTINUOUS STEEL ANGLE AS SPECIFIED

GYPSUM BOARD FINISHED/FIRE STOP INSTALLED AT JOISTS AS PER CODE

COMPOSITE STEEL ROOF DECK

U BRACKET ANCHOR INSERT

OWSJ

WET SET DOWELS TO MATCH VERTICAL REINFORCEMENT BETWEEN POUR OR AS SPECIFIED

INTERIOR INSULATION REMOVED AT JOIST LOCATIONS

HORIZ/VERT REINFORCEMENT AS PER CODE OR AS SPECIFIED

1/2" (13mm) GYPSUM BOARD

NUDURA 6" (152mm) STANDARD FORM UNIT

DISCLAIMER NOTICE:  
SPECIFIC INFORMATION  
REQUIRED FOR COMPLIANCE  
WITH LOCAL CODES IS THE  
RESPONSIBILITY OF THE  
DESIGNER



# NUDURA

INTEGRATED BUILDING TECHNOLOGY

*Building Value.*

NUDURA 6" (152mm) FORM UNIT  
STEEL JOIST ROOF DETAIL  
BEARING WALL  
EXTERIOR FINISH AS SPECIFIED

REV. NO.  
005 KS

DATE:  
APRIL 2010

DRAWN BY:  
J. NEILON

DWG NO.

F6C01

SCALE:  
1 : 8