

FLASHING AS SPECIFIED

NON-COMBUSTIBLE FIBERGLASS BATT INSULATION ON VAPOR BARRIER

EXTERIOR FINISH AS SPECIFIED

FORM PANELS c/w INSERT WEBS- CUT TO SUIT ROOF CONNECTION- ADDITIONAL FORM SUPPORT AS REQUIRED

ALLOW ROOF SLAB TO REST ON TO BEARING WALL CONCRETE

WET SET DOWELS TO MATCH VERTICAL REINFORCEMENT BETWEEN POUR OR AS SPECIFIED

NUDURA 12" (305mm) STANDARD FORM UNIT

HORIZ/VERT REINFORCEMENT AS PER CODE OR AS SPECIFIED

WOOD BLOCKING AND PLYWOOD AT 5° SLOPE

EPS CANT STRIP

FIBER BOARD SUBSTRATE w/ ROOF MEMBRANE ON 3 1/2" (89mm) RIGID INSULATION

PROPRIETARY STEEL JOIST FLOOR SYSTEM

CEILING FINISH AS PER STEEL JOIST MANUFACTURERS SPECIFICATION (NOTE: WHERE GYPSUM BOARD IS REQUIRED TO COMPLETE FIRE RATED ASSEMBLY, EPS FOAM KERF CUT TO ENABLE CEILING FINISH TO PROVIDE THERMAL BARRIER CONTACT TO CONCRETE)

1/2" (13mm) GYPSUM BOARD

DISCLAIMER NOTICE:
SPECIFIC INFORMATION
REQUIRED FOR COMPLIANCE
WITH LOCAL CODES IS THE
RESPONSIBILITY OF THE
DESIGNER



NUDURA

INTEGRATED BUILDING TECHNOLOGY

Building Value.

NUDURA 12" (305mm) FORM UNIT
STEEL JOIST ROOF SYSTEM
EXTERIOR SIDE WALL
EXTERIOR FINISH AS SPECIFIED

REV. NO.
003 KS

DATE:
APRIL 2010

DRAWN BY:
T. VAN CLIEAF

DWG NO.
F12F04

SCALE:
1 : 8