

FLASHING AS SPECIFIED

WOOD BLOCKING AND PLYWOOD AT 5° SLOPE

NON-COMBUSTIBLE FIBERGLASS BATT INSULATION ON VAPOR BARRIER

EXTERIOR FINISH AS SPECIFIED

EPS CANT STRIP

FIBER BOARD SUBSTRATE w/ ROOF MEMBRANE ON 3 1/2" (89mm) RIGID INSULATION

CONTINUOUS STEEL ANGLE AS SPECIFIED

GYPSUM BOARD FINISHED/FIRE STOP INSTALLED AT JOISTS AS PER CODE

COMPOSITE STEEL ROOF DECK

U BRACKET ANCHOR INSERT

OWSJ

WET SET DOWELS TO MATCH VERTICAL REINFORCEMENT BETWEEN POUR OR AS SPECIFIED

INTERIOR INSULATION REMOVED AT JOIST LOCATIONS

HORIZ/VERT REINFORCEMENT AS PER CODE OR AS SPECIFIED

1/2" (13mm) GYPSUM BOARD

NUDURA 10" (254mm) STANDARD FORM UNIT

DISCLAIMER NOTICE:
SPECIFIC INFORMATION
REQUIRED FOR COMPLIANCE
WITH LOCAL CODES IS THE
RESPONSIBILITY OF THE
DESIGNER



NUDURA

INTEGRATED BUILDING TECHNOLOGY

Building Value.

NUDURA 10" (254mm) FORM UNIT
STEEL JOIST ROOF DETAIL
BEARING WALL
EXTERIOR FINISH AS SPECIFIED

REV. NO.
004 KS

DWG NO.
F10C04

DATE:
APRIL 2010

DRAWN BY:
T. VAN CLIEAF

SCALE:
1 : 8