

FLASHING AS SPECIFIED

WOOD BLOCKING AND PLYWOOD AT 5° SLOPE

NON-COMBUSTIBLE FIBERGLASS BATT INSULATION ON VAPOR BARRIER

BRICK VENEER c/w 1" (25mm) AIR SPACE AND BRICK TIES

CONTINUOUS STEEL ANGLE AS SPECIFIED

GYPSUM BOARD FINISHED/FIRE STOP INSTALLED AT JOISTS AS PER CODE

U BRACKET ANCHOR INSERT

WET SET DOWELS TO MATCH VERTICAL REINFORCEMENT BETWEEN POUR OR AS SPECIFIED

HORIZ/VERT REINFORCEMENT AS PER CODE OR AS SPECIFIED

EPS CANT STRIP

FIBER BOARD SUBSTRATE w/ ROOF MEMBRANE ON 3 1/2" (89mm) RIGID INSULATION

COMPOSITE STEEL ROOF DECK

OWSJ

INTERIOR INSULATION REMOVED AT JOIST LOCATIONS

1/2" (13mm) GYPSUM BOARD

NUDURA 8" (203mm) STANDARD FORM UNIT

DISCLAIMER NOTICE:
SPECIFIC INFORMATION
REQUIRED FOR COMPLIANCE
WITH LOCAL CODES IS THE
RESPONSIBILITY OF THE
DESIGNER



NUDURA 8" (203mm) FORM UNIT
STEEL JOIST ROOF DETAIL
BEARING WALL
BRICK VENEER FINISH

REV. NO. 004 KS	DWG NO. F8C11
DATE: APRIL 2010	
DRAWN BY: T. VAN CLIEAF	SCALE: 1 : 8