

FLASHING AS SPECIFIED

WOOD BLOCKING AND PLYWOOD AT 5° SLOPE

NON-COMBUSTIBLE FIBERGLASS BATT INSULATION ON VAPOR BARRIER

BRICK VENEER c/w 1" (25mm) AIR SPACE AND BRICK TIES

EPS CANT STRIP

FIBER BOARD SUBSTRATE w/ ROOF MEMBRANE ON 3 1/2" (89mm) RIGID INSULATION

COMPOSITE STEEL DECK

STEEL DECK SUPPORT WELDING ANCHOR INSERT

INTERIOR INSULATION TO BE DISCONTINUOUS AT FLOOR LINES

HORIZ/VERT REINFORCEMENT AS PER CODE OR AS SPECIFIED

NUDURA 6" (152mm) STANDARD FORM UNIT

MIN. 1/32" (0.8mm) x 2 1/2" (63.5mm) GALVANIZED STEEL CHANNEL CAP TO PROVIDE THERMAL BARRIER PROTECTION

WET SET DOWELS TO MATCH VERTICAL REINFORCEMENT BETWEEN POUR OR AS SPECIFIED

PROVIDE 4"x4" (100mmx100mm) FORM CUT OUT AT BRIDGING LOCATIONS

CLIP ANGLE ANCHORED TO WALL AT JOIST BRIDGING LOCATIONS

1/2" (13mm) GYPSUM BOARD

DISCLAIMER NOTICE: SPECIFIC INFORMATION REQUIRED FOR COMPLIANCE WITH LOCAL CODES IS THE RESPONSIBILITY OF THE DESIGNER



NUDURA

INTEGRATED BUILDING TECHNOLOGY

Building Value.

NUDURA 6" (152mm) FORM UNIT STEEL JOIST ROOF DETAIL SIDE WALL BRICK VENEER FINISH

REV. NO. 003 KS
DATE: APRIL 2010
DRAWN BY: J. NEILON

DWG NO. F6C04
SCALE: 1 : 8