

**DISCLAIMER NOTICE:**  
 SPECIFIC INFORMATION  
 REQUIRED FOR COMPLIANCE  
 WITH LOCAL CODES IS THE  
 RESPONSIBILITY OF THE  
 DESIGNER

HEIGHT OF PARAPET TO BE  
 DETERMINED BY  
 ENGINEERING DESIGN

MIN.  $\frac{5}{8}$ " (16mm) CEMENT  
 BOARD PANELS TO BE  
 INSTALLED PREPOUR AS  
 FORM PANEL FOR  
 CONCRETE CAP AT TOP OF  
 WALL INSTALLED ON SLOPE  
 TO MATCH ROOF PITCH

COMPOSITE STEEL  
 DECK

COMPOSITE STEEL DECK  
 WELDED TO SUPPORT  
 ANCHORS AS SPECIFIED

HORIZ/VERT  
 REINFORCEMENT AS PER  
 CODE OR AS SPECIFIED

WET SET DOWELS TO  
 MATCH VERTICAL  
 REINFORCEMENT  
 BETWEEN POUR OR  
 AS SPECIFIED

PROVIDE 4"x4"  
 (100mmx100mm)  
 FORM CUT OUT AT  
 BRIDGING LOCATIONS

NUDURA 10" (254mm)  
 STANDARD FORM UNIT

CAP FLASHING CLIPPED TO  
 COUNTER FLASHING

ADDITIONAL FORM  
 SUPPORT AT CEMENT  
 BOARD PANELS AS  
 REQUIRED

MIN. 6" (152mm) THICK  
 CONTINUOUS CONCRETE  
 CAP AT TOP OF WALL  
 POURED INTEGRAL WITH  
 FIREWALL OR AS PER  
 LOCAL CODE

EPS CANT STRIP

FIBER BOARD SUBSTRATE  
 w/ ROOF MEMBRANE  
 ON 3  $\frac{1}{2}$ " (89mm) RIGID  
 INSULATION

INTERIOR INSULATION  
 TO BE DISCONTINUOUS  
 AT FLOOR LINES

OWSJ

MIN.  $\frac{1}{32}$ " (0.8mm) x 2  $\frac{1}{2}$ "  
 (63.5mm) GALVANIZED  
 STEEL CHANNEL CAP TO  
 PROVIDE THERMAL BARRIER  
 PROTECTION

CLIP ANGLE ANCHORED  
 TO WALL AT JOIST  
 BRIDGING LOCATIONS

$\frac{1}{2}$ " (13mm) GYPSUM  
 BOARD



**NUDURA**

INTEGRATED BUILDING TECHNOLOGY

*Building Value.*

NUDURA 10" (254mm) FORM UNIT  
 STEEL JOIST ROOF DETAIL  
 NON-BEARING DEMISING WALL

REV. NO.  
000

DATE:  
APRIL 2010

DRAWN BY:  
K. STILL

DWG. NO.

G10C04

SCALE:

1 : 8