

HEIGHT OF PARAPET TO BE DETERMINED BY ENGINEERING DESIGN

CAP FLASHING CLIPPED TO COUNTER FLASHING

ADDITIONAL FORM SUPPORT AT CEMENT BOARD PANELS AS REQUIRED

MIN. $\frac{5}{8}$ " (16mm) CEMENT BOARD PANELS TO BE INSTALLED PREPOUR AS FORM PANEL FOR CONCRETE CAP AT TOP OF WALL INSTALLED ON SLOPE TO MATCH ROOF PITCH

MINIMUM 6" (152mm) THICK CONTINUOUS CONCRETE CAP AT TOP OF WALL POURED INTEGRAL WITH FIREWALL OR AS PER LOCAL CODE

CONTINUOUS STEEL ANGLE AS SPECIFIED

EPS CANT STRIP

GYPSUM BOARD FINISHED/FIRE STOP INSTALLED AT JOISTS AS PER CODE

FIBER BOARD SUBSTRATE w/ ROOF MEMBRANE ON 3 $\frac{1}{2}$ " (89mm) RIGID INSULATION

U BRACKET ANCHOR INSERT

COMPOSITE STEEL ROOF DECK

OWSJ

WET SET DOWELS TO MATCH VERTICAL REINFORCEMENT BETWEEN POUR OR AS SPECIFIED
HORIZ/VERT REINFORCEMENT AS PER CODE OR AS SPECIFIED

INTERIOR INSULATION REMOVED AT JOIST LOCATIONS

$\frac{1}{2}$ " (13mm) GYPSUM BOARD

NUDURA 8" (203mm) STANDARD FORM UNIT

DISCLAIMER NOTICE:
SPECIFIC INFORMATION REQUIRED FOR COMPLIANCE WITH LOCAL CODES IS THE RESPONSIBILITY OF THE DESIGNER



NUDURA

INTEGRATED BUILDING TECHNOLOGY

Building Value.

NUDURA 8" (203mm) FORM UNIT
STEEL JOIST ROOF DETAIL
BEARING DEMISING WALL

REV. NO.
000

DATE:
APRIL 2010

DRAWN BY:
K. STILL

DWG NO.

G8C03

SCALE:

1 : 8